



cfo@suratmunicipal.org



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOSMC/2023/00035150
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOSMC/2023/00035150/R1

Date: 14/10/2025

Building Occupancy/Category: Educational (non-residential)

To,

VIRENDRA NERKAR
GD GOENKA INTERNATIONAL SCHOOL VESU surat Surat MC 395007
Fire Region: Surat MC
Mobile No: 9913870797 Email ID: security.incharge@gdgoenkasurat.com

We have received Application No. **2025/00144341** dated 08/10/2025 for Fire Safety Certificate Renewal (FSCR) - New Building(FSCR)/Existing Building (FSCRe) for the building/premise **GD GOENKA INTERNATIONAL SCHOOL (name of the Building/ Project)**, as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: surat
5. Name of Block(s): GD GOENKA INTERNATIONAL SCHOOL


The building/premise was inspected on **14/10/2025** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **14/10/2025**
2. Six monthly inspection was done on **14/10/2025**

The Fire Safety Certificate is renewed for a **period of two (2) years upto 20/10/2027** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated: **13/10/2025 7:05:58 PM**



Digitally Verified

Digitally verified by: Girishkumar Bhavanishankar Upadhyay
Fire Safety Officer - Specialist (FSO-S)
2021/001568
Reviewed by : CFO Surat MC
Date: 14/10/2025
Time: 11:35 AM



FSCA/O/CFOSMC/2023/00035150/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetypcop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.



Gujarat Fire Safety CoP

Application Inspection Report

Application No

2025/00144341

A. Applicant/ Owner/ Builder/ Occupier Details

Name of Owner/ Developer/ Builder/ Occupier	Mobile Number of Owner/ Developer/ Builder	Email ID of Owner/ Developer/ Builder
GD GOENKA INTERNATIONAL SCHOOL	0991387079 #Error	#Error
District	Plot/ House No., Building/ Company/ Apartment Name/ No.	Area/ Colony/ Street/ Sector/ Ward/ Village
Surat	WISDOM VALLEY CAMPUS, CANAL ROAD, NEAR ANUVRAT DWAR, VESU-BHARTHANA, SURAT-395007	WISDOM VALLEY CAMPUS, CANAL ROAD, NEAR ANUVRAT DWAR, VESU-BHARTHANA, SURAT-395007
Landmark	Taluka	Pin Code
	surat	395007
Architect on Record(AoR)/Engineer on Record(EoR) Name	Architect on Record(AoR)/Engineer on Record(EoR) Registration No	

Compliance Status

Compliance/ Non Compliance	Remarks
Compliance	

B. Site Details

Name of Building/ Project/ Scheme	Select Area of Building/ Project/ Scheme	District
GD GOENKA INTERNATIONAL SCHOOL	Municipal Corporation Area	Surat MC
Taluka	Urban Local Body (ULB)	Zone
	Surat Municipal Corporation	South West Zone
Ward	Plot/ House No., Building/ Company/ Apartment Name/ No.	Area/ Colony/ Street/ Sector/ Society
BHATAR-VESU-DUMAS	GD GOENKA INTERNATIONAL SCHOOL	VESU
Landmark	Taluka/ City/ Village	Pin Code
	surat	395007
Lattitude	Longitude	TP Number
21.1540657	72.7917983	
FP Number	Survey Number	Sub Ploat Number

Compliance Status

Compliance/ Non Compliance	Remarks
Compliance	

C. Building/Project Details

Principle Occupancy/Use of Building/Project/Scheme	Site Area/ Plot Area of Building/ Project/ Scheme (In Sq. Mtrs)
Educational (non-residential)	32642.00
Approach to Building/Project/Scheme i.e. width of the road and connecting roads, if any (in Mtrs)	Enter Number of Building Block(s)
0.00	1
Width of the main entrance gate of the Building/Project/Scheme (in Mtrs)	Height of the main entrance gate/arch of the Building/Project/Scheme (in Mtrs)

Building Block Name	Main Occupancy Occupancy Sub Division Building Sub Category	Building Height From ground level to top most slab (excluding parapet)	Total Floor Area (in Sq. Mtrs)	Built up area (in Mtrs)	Assembly Occupancy Type Assembly Capacity (number of persons allowed) (applicable only for Assembly Occupancy Building types)
GD GOENKA INTERNATIONAL SCHOOL	Educational (non-residential) Educational (School/College) Building Height >15m but less than 30m	16.20	32642.80	32642.80	
Compliance Status					
Compliance/ Non Compliance			Remarks		
Compliance					
D. Building/Block Details					
GD GOENKA INTERNATIONAL SCHOOL					
		Inputs		Compliance/ Non Compliance FSO Remarks	
D1.1	No. of floors (including basement floors)	5			
D1.2	Minimum margin between this building block and any other adjacent building block (s), if any (in Mtrs)			Compliance	
D1.3	Roadside margin of this building block (in Mtrs)			Compliance	
D1.4	Rear/back and side margin of this building block (in Mtrs)			Compliance	
D1.5	Approach to this building block (width of the road or connecting roads), if any (in Mtrs)			Compliance	
D1.6	Maximum available width of clear motorable open space/road on the front and sides of this building block (in Mtrs)			Compliance	
D1.7	Details/Features of surrounding property (particularly such features like – hazardous occupations like hazardous storage, petrol pump, with details of such occupations with direction i.e. north, south etc)			Compliance	
E. Fire Prevention					
GD GOENKA INTERNATIONAL SCHOOL					
		Inputs		Compliance/ Non Compliance FSO Remarks	
Service Ducts					
E1.1	Are there any service ducts in this building block?	To be checked by FSO		Compliance No separate	
E1.1.1	Have internal service ducts and shafts been properly enclosed by fire resistant walls and doors, so that potential fire spread can be stopped at all floor levels?			Compliance	
E1.1.2	All internal service ducts and shafts have a vent opening at the top?			Compliance	

Sub-Stations/ Transformers

E1.2		Is there any sub station or transformer for this building block?	To be checked by FSO	Compliance No
	E1.2.1	Number of transformers		Compliance
	E1.2.2	Type and capacity of transformers?		Compliance
	E1.2.3	Location of transformers (inside/ outside building)		Compliance
	E1.2.4	Type of fire protection systems provided for transformers, if any		Compliance
	E1.2.5	Is there any substation also in this building block?		Compliance

Standby Power supply

E1.3		Is there any type of stand by power supply or generator etc provided for the building block?	To be checked by FSO	Compliance Yes
	E1.3.1	Is generator or power supply automatic in action?		Compliance

Lifts & Fireman Lifts

E1.4		How many lifts have been installed in the building, and how many are designated fire lifts?		
	E1.4.1	No. of Total Lifts	1	Compliance
	E1.4.2	No. of Fire Lifts	1	Compliance

Ventilation & Air conditioning

E1.5.1		Whether natural ventilation or mechanical ventilation is provided?	Natural	Compliance
--------	--	--	---------	------------

Compartmentation

E1.6.1		Whether any compartmentation has been done in the building?	To be checked by FSO	Compliance Each room and floors are separate
--------	--	---	----------------------	---

Lightning Arrestor

E1.7.1		Whether a lightning arrestor has been installed?	To be checked by FSO	Compliance Yes
--------	--	--	----------------------	-------------------

Other Systems

E1.8.1		Are any other building systems such as boiler room, gas supply, refuse chutes provided for the building?		Compliance
--------	--	--	--	------------

F. Life Safety**GD GOENKA INTERNATIONAL SCHOOL**

			Inputs	Compliance/ Non Compliance FSO Remarks
Staircase				
F1.1.1		Number of internal staircases that have been provided in the building block	1	Compliance
F1.1.2		Number of external staircases that have been provided in the building	1	Compliance
Doorways				
F1.2.1		Have fire exit doors been provided in building?	To be checked by FSO	Compliance No

Basement				
F1.3		Are there any basements in the building?	To be checked by FSO	Compliance No
	F1.3.1	How many basements provided?		Compliance
	F1.3.2	Are basements sprinklered?		Compliance
	F1.3.3	Type of ventilation provided for basements		Compliance
Emergency Lighting/ Exit Signage				
F1.4.1		Whether adequate illumination with alternate power supply is provided for safe movement of persons towards and through the exits?	To be checked by FSO	Compliance Natural
F1.4.2		Whether proper exit signage has been provided in exit access area to provide clear directions to people moving towards exits?	To be checked by FSO	Compliance Yes
G.Fire protection				
GD GOENKA INTERNATIONAL SCHOOL				
		Inputs	Compliance/ Non Compliance FSO Remarks	
Fire Detection and Alarm				
G1.1.1		Is the building provided with Automatic Fire Detection and Alarm system (AFDA)/ Manually Operated Fire Alarm system (MOEFA)?	AFDA	Compliance
Fire fighting Installations				
G1.2.1		Have portable fire extinguishers (as per IS:2190 or as per the relevant/latest India Standards (IS)) been provided?	To be checked by FSO	Compliance Yes
	G1.2.2	If yes, then number of portable fire extinguishers (type wise)		Compliance 30 no's of Co2 and 105 no's of ABC
G1.2.3		Has first aid hose reel been provided?	To be checked by FSO	Compliance Yes
G1.2.4		Has the wet riser/ downcomer system, been provided?	To be checked by FSO	Compliance Yes
G1.2.5		Have yard hydrants been provided?	To be checked by FSO	Compliance No
G1.2.6		Has automatic sprinkler system been provided?	To be checked by FSO	Compliance No
Fire Fighting Pumps				
G1.4.1		Provide capacity of firefighting pumps, if available (No. of firefighting pumps and type)		Compliance
Special Fire protection systems				
G1.5.1		Special fire protection system provided, if any (water spray, foam, water mist, clean agent, etc)		Compliance
Water Supply				
G1.3.1		Type of fire water storage tank provided	Underground	Compliance
G1.3.2		Provided capacity of fire water storage tank (in ltr)	75000	Compliance
H. Occupancy Specific & Other Requirements				
GD GOENKA INTERNATIONAL SCHOOL				

		Inputs	Compliance/ Non Compliance FSO Remarks
Life Safety			
H1.1	Is there any hazardous material in the building? If information available, please enter details.		Compliance
I. Attachment			
Document			Attachment Provided?
Common Document			
I1	Final Layout plan of Building complex/ Factory (showing Fire Vehicle Access)		No
I2	Inspection Report / Checklist / Rojkam done by Fire Department during Inspection and along any other documents which capture the details of fire protection and fire safety related information about the building		Yes
I3	Undertaking on Affidavit by the Owner/ Occupier/ Builder/ Developer for maintaining Fire Protection System as per approved fire safety certificate and no alteration of any part of the building without approval of the competent authority (Renewed)		No
I4	Existing NoC		Yes
I5	Fire Safety Plan		No
Building Block Level Document: GD GOENKA INTERNATIONAL SCHOOL			
B1	Duly Notarised Annual Maintenance Contract for Fire Protection System Installed (Renewed)		No
B2	Valid Fire Lift License Certificate		No